

I n t e r n a t i o n a l T e l e c o m m u n i c a t i o n U n i o n

ITU-T

TELECOMMUNICATION
STANDARDIZATION SECTOR
OF ITU

H.830.16

(10/2019)

SERIES H: AUDIOVISUAL AND MULTIMEDIA SYSTEMS

E-health multimedia systems, services and applications –
Interoperability compliance testing of personal health
systems (HRN, PAN, LAN, TAN and WAN)

**Conformance of ITU-T H.810 personal health
system: Services interface Part 16: FHIR
Observation Upload: Health & Fitness Service
receiver**

Recommendation ITU-T H.830.16



ITU-T H-SERIES RECOMMENDATIONS
AUDIOVISUAL AND MULTIMEDIA SYSTEMS

CHARACTERISTICS OF VISUAL TELEPHONE SYSTEMS	H.100–H.199
INFRASTRUCTURE OF AUDIOVISUAL SERVICES	
General	H.200–H.219
Transmission multiplexing and synchronization	H.220–H.229
Systems aspects	H.230–H.239
Communication procedures	H.240–H.259
Coding of moving video	H.260–H.279
Related systems aspects	H.280–H.299
Systems and terminal equipment for audiovisual services	H.300–H.349
Directory services architecture for audiovisual and multimedia services	H.350–H.359
Quality of service architecture for audiovisual and multimedia services	H.360–H.369
Telepresence, immersive environments, virtual and extended reality	H.420–H.439
Supplementary services for multimedia	H.450–H.499
MOBILITY AND COLLABORATION PROCEDURES	
Overview of Mobility and Collaboration, definitions, protocols and procedures	H.500–H.509
Mobility for H-Series multimedia systems and services	H.510–H.519
Mobile multimedia collaboration applications and services	H.520–H.529
Security for mobile multimedia systems and services	H.530–H.539
Security for mobile multimedia collaboration applications and services	H.540–H.549
VEHICULAR GATEWAYS AND INTELLIGENT TRANSPORTATION SYSTEMS (ITS)	
Architecture for vehicular gateways	H.550–H.559
Vehicular gateway interfaces	H.560–H.569
BROADBAND, TRIPLE-PLAY AND ADVANCED MULTIMEDIA SERVICES	
Broadband multimedia services over VDSL	H.610–H.619
Advanced multimedia services and applications	H.620–H.629
Ubiquitous sensor network applications and Internet of Things	H.640–H.649
IPTV MULTIMEDIA SERVICES AND APPLICATIONS FOR IPTV	
General aspects	H.700–H.719
IPTV terminal devices	H.720–H.729
IPTV middleware	H.730–H.739
IPTV application event handling	H.740–H.749
IPTV metadata	H.750–H.759
IPTV multimedia application frameworks	H.760–H.769
IPTV service discovery up to consumption	H.770–H.779
Digital Signage	H.780–H.789
E-HEALTH MULTIMEDIA SYSTEMS, SERVICES AND APPLICATIONS	
Personal health systems	H.810–H.819
Interoperability compliance testing of personal health systems (HRN, PAN, LAN, TAN and WAN)	H.820–H.859
Multimedia e-health data exchange services	H.860–H.869
Safe listening	H.870–H.879

For further details, please refer to the list of ITU-T Recommendations.

Recommendation ITU-T H.830.16

Conformance of ITU-T H.810 personal health system: Services interface Part 16: FHIR Observation Upload: Health & Fitness Service receiver

Summary

Recommendation ITU-T H.830.16 provides a test suite structure (TSS) and the test purposes (TPs) for fast healthcare interoperability resource (FHIR) Observation Upload through the Health & Fitness Service (HFS) receiver in the Services interface, based on the requirements defined in the Recommendations of the ITU-T H.810 sub-series, of which Recommendation ITU-T H.810 (2017) is the base Recommendation. The objective of this test specification is to provide a high probability of interoperability at this interface.

Recommendation ITU-T H.830.16 includes an electronic attachment with the protocol implementation conformance statements (PICSs) and the protocol implementation extra information for testing (PIXIT) required for the implementation of Annex A.

History

Edition	Recommendation	Approval	Study Group	Unique ID*
1.0	ITU-T H.830.16	2018-08-29	16	11.1002/1000/13677
2.0	ITU-T H.830.16	2019-10-17	16	11.1002/1000/14097

Keywords

Conformance testing, Continua Design Guidelines, e-health, Health & Fitness Service, ITU-T H.810, personal connected health devices, Services interface, Capability Exchange, FHIR Observation Upload.

* To access the Recommendation, type the URL <http://handle.itu.int/> in the address field of your web browser, followed by the Recommendation's unique ID. For example, <http://handle.itu.int/11.1002/1000/11830-en>.

FOREWORD

The International Telecommunication Union (ITU) is the United Nations specialized agency in the field of telecommunications, information and communication technologies (ICTs). The ITU Telecommunication Standardization Sector (ITU-T) is a permanent organ of ITU. ITU-T is responsible for studying technical, operating and tariff questions and issuing Recommendations on them with a view to standardizing telecommunications on a worldwide basis.

The World Telecommunication Standardization Assembly (WTSA), which meets every four years, establishes the topics for study by the ITU-T study groups which, in turn, produce Recommendations on these topics.

The approval of ITU-T Recommendations is covered by the procedure laid down in WTSA Resolution 1.

In some areas of information technology which fall within ITU-T's purview, the necessary standards are prepared on a collaborative basis with ISO and IEC.

NOTE

In this Recommendation, the expression "Administration" is used for conciseness to indicate both a telecommunication administration and a recognized operating agency.

Compliance with this Recommendation is voluntary. However, the Recommendation may contain certain mandatory provisions (to ensure, e.g., interoperability or applicability) and compliance with the Recommendation is achieved when all of these mandatory provisions are met. The words "shall" or some other obligatory language such as "must" and the negative equivalents are used to express requirements. The use of such words does not suggest that compliance with the Recommendation is required of any party.

INTELLECTUAL PROPERTY RIGHTS

ITU draws attention to the possibility that the practice or implementation of this Recommendation may involve the use of a claimed Intellectual Property Right. ITU takes no position concerning the evidence, validity or applicability of claimed Intellectual Property Rights, whether asserted by ITU members or others outside of the Recommendation development process.

As of the date of approval of this Recommendation, ITU had not received notice of intellectual property, protected by patents, which may be required to implement this Recommendation. However, implementers are cautioned that this may not represent the latest information and are therefore strongly urged to consult the TSB patent database at <http://www.itu.int/ITU-T/ipr/>.

© ITU 2019

All rights reserved. No part of this publication may be reproduced, by any means whatsoever, without the prior written permission of ITU.

Table of Contents

	Page
1 Scope.....	1
2 References.....	1
3 Definitions	2
3.1 Terms defined elsewhere	2
3.2 Terms defined in this Recommendation	2
4 Abbreviations and acronyms	2
5 Conventions	3
6 Test suite structure	4
7 Electronic attachment	7
Annex A Test procedures.....	8
A.1 Test purpose definition conventions.....	8
A.2 Subgroup 2.9.1: General (GEN).....	9
Bibliography.....	16

Electronic attachment: This Recommendation includes an electronic attachment with the protocol implementation conformance statements (PICSS) and the protocol implementation extra information for testing (PIXIT) required for the implementation of Annex A.

Introduction

The table below shows the revision history of this test specification.

Version	Date	Revision history
1.0	2018-02-27	Initial release for the inclusion of FHIR Observation Upload for Health & Fitness Service receivers.
1.1	2019-06-13	Second maintenance release for Test Tool DG2017. It uses "H.830.16_201808" as a baseline and adds some updates according to the 2018/2019 maintenance activity.

Recommendation ITU-T H.830.16

Conformance of ITU-T H.810 personal health system: Services interface Part 16: FHIR Observation Upload: Health & Fitness Service receiver

1 Scope

The scope of this Recommendation¹ is to provide a test suite structure (TSS) and the test purposes (TPs) for the Services interface based on the requirements defined in Continua Design Guidelines (CDG) [ITU-T H.810 (2017)]. The objective of this test specification is to provide a high probability of interoperability at this interface.

The TSS and TPs for the Services interface have been divided into the parts specified below. This Recommendation covers Part 16.

- Part 1: Web services interoperability. Health & Fitness Service sender
- Part 2: Web services interoperability. Health & Fitness Service receiver
- Part 3: SOAP/ATNA. Health & Fitness Service sender
- Part 4: SOAP/ATNA. Health & Fitness Service receiver
- Part 5: PCD-01 HL7 Messages. Health & Fitness Service sender
- Part 6: PCD-01 HL7 Messages. Health & Fitness Service receiver
- Part 7: Consent Management. Health & Fitness Service sender
- Part 8: Consent Management. Health & Fitness Service receiver
- Part 9: hData Observation Upload. Health & Fitness Service sender
- Part 10: hData Observation Upload. Health & Fitness Service receiver
- Part 11: Questionnaires. Health & Fitness Service sender
- Part 12: Questionnaires. Health & Fitness Service receiver
- Part 13: Capability Exchange. Health & Fitness Service sender
- Part 14: Capability Exchange. Health & Fitness Service receiver
- Part 15: FHIR Observation Upload. Health & Fitness Service sender
- **Part 16: FHIR Observation Upload. Health & Fitness Service receiver**

2 References

The following ITU-T Recommendations and other references contain provisions which, through reference in this text, constitute provisions of this Recommendation. At the time of publication, the editions indicated were valid. All Recommendations and other references are subject to revision; users of this Recommendation are therefore encouraged to investigate the possibility of applying the most recent edition of the Recommendations and other references listed below. A list of the currently valid ITU-T Recommendations is regularly published. The reference to a document within this Recommendation does not give it, as a stand-alone document, the status of a Recommendation.

[ITU-T H.810 (2017)] Recommendation ITU-T H.810 (2017), *Interoperability design guidelines for personal connected health systems: Introduction*.

¹ This Recommendation includes an electronic attachment with the protocol implementation conformance statements (PICS) and the protocol implementation extra information for testing (PIXIT) required for the implementation of Annex A.

3 Definitions

3.1 Terms defined elsewhere

None.

3.2 Terms defined in this Recommendation

None.

4 Abbreviations and acronyms

This Recommendation uses the following abbreviations and acronyms:

ATNA	Audit Trail and Node Authentication
CDG	Continua Design Guidelines
CGM	Continuous Glucose Monitor
DUT	Device Under Test
FHIR	Fast Healthcare Interoperability Resource
HFS	Health & Fitness Service
HFSS	Health & Fitness Service Sender
HFSR	Health & Fitness Service Receiver
HL7	Health Level 7
HTTP	Hypertext Transfer Protocol
INR	International Normalized Ratio
IP	Insulin Pump
JSON	JavaScript Object Notation
PCD	Patient Care Device
PHG	Personal Health Gateway
PICS	Protocol Implementation Conformance Statement
PIXIT	Protocol Implementation extra Information for Testing
SABTE	Sleep Apnoea Breathing Therapy Equipment
SCR	Static Conformance Review
SOAP	Simple Object Access Protocol
TLS	Transport Level Security
TP	Test Purpose
TSS	Test Suite Structure
WSI	Web Services Interoperability
XDR	cross-enterprise Document Reliable interchange
XML	extensible Markup Language

5 Conventions

The key words "SHALL", "SHALL NOT", "SHOULD", "SHOULD NOT", "MAY", "MAY NOT" in this Recommendation are to be interpreted as in [b-ETSI SR 001 262].

- SHALL is equivalent to 'must' or 'it is required to'.
- SHALL NOT is equivalent to 'must not' or 'it is not allowed'.
- SHOULD is equivalent to 'it is recommended to'.
- SHOULD NOT is equivalent to 'it is not recommended to'.
- MAY is equivalent to 'is permitted'.
- MAY NOT is equivalent to 'it is not required that'.

NOTE – The above-mentioned key words are capitalized for illustrative purposes only and they do not appear capitalized within this Recommendation.

Reference is made in the ITU-T H.800-series of Recommendations to different versions of the Continua Design Guidelines (CDG) by a specific designation. The list of terms that may be used in this Recommendation is provided in Table 1.

Table 1 – List of designations associated with the various versions of the CDG

CDG release	Transposed as	Version	Description	Designation
2017	–	7.0	Release 2017 of the CDG including maintenance updates of the CDG 2016 and additional guidelines that cover new functionalities.	–
2016 plus errata	[ITU-T H.810 (2016)]	6.1	Release 2016 plus errata noting all ratified bugs [b-CDG 2016].	–
2016	–	6.0	Release 2016 of the CDG including maintenance updates of the CDG 2015 and additional guidelines that cover new functionalities.	Iris
2015 plus errata	[b-ITU-T H.810 (2015)]	5.1	Release 2015 plus errata noting all ratified bugs [b-CDG 2015]. The 2013 edition of [ITU-T H.810] is split into eight parts in the ITU-T H.810 series.	–
2015	–	5.0	Release 2015 of the CDG including maintenance updates of the CDG 2013 and additional guidelines that cover new functionalities.	Genome
2013 plus errata	[b-ITU-T H.810 (2013)]	4.1	Release 2013 plus errata noting all ratified bugs [b-CDG 2013].	–
2013	–	4.0	Release 2013 of the CDG including maintenance updates of the CDG 2012 and additional guidelines that cover new functionalities.	Endorphin

CDG release	Transposed as	Version	Description	Designation
2012 plus errata	–	3.1	Release 2012 plus errata noting all ratified bugs [b-CDG 2012].	–
2012	–	3.0	Release 2012 of the CDG including maintenance updates of the CDG 2011 and additional guidelines that cover new functionalities.	Catalyst
2011 plus errata	–	2.1	CDG 2011 integrated with identified errata.	–
2011	–	2.0	Release 2011 of the CDG including maintenance updates of the CDG 2010 and additional guidelines that cover new functionalities [b-CDG 2011].	Adrenaline
2010 plus errata	–	1.6	CDG 2010 integrated with identified errata	–
2010	–	1.5	Release 2010 of the CDG with maintenance updates of the CDG Version 1 and additional guidelines that cover new functionalities [b-CDG 2010].	1.5
1.0	–	1.0	First released version of the CDG [b-CDG 1.0].	–

6 Test suite structure

The test purposes (TPs) for the Services interface have been divided into the main subgroups specified below. Annex A describes the TPs for subgroups 2.7.1, 2.7.2 and 2.7.3 (shown in bold):

- Group 1: HFS sender (HFSS)
 - Group 1.1: Web services interoperability (WSI)
 - Subgroup 1.1.1: Basic profile (BP)
 - Subgroup 1.1.2: Basic security profile (BSP)
 - Subgroup 1.1.3: Reliable messaging (RM)
 - Group 1.2: Simple object access protocol (SOAP)
 - Subgroup 1.2.1: SOAP headers (HEAD)
 - Group 1.3: Audit trail and node authentication (ATNA)
 - Subgroup 1.3.1: General (GEN)
 - Subgroup 1.3.2: PCD-01 (PCD-01)
 - Subgroup 1.3.3: Consent Management (CM)
 - Group 1.4: PCD-01 HL7 messages (PCD-01-DATA)
 - Subgroup 1.4.1: General (GEN)
 - Subgroup 1.4.2: Design guidelines (DG)
 - Subgroup 1.4.3: Pulse oximeter (PO)
 - Subgroup 1.4.4: Blood pressure monitor (BPM)
 - Subgroup 1.4.5: Thermometer (TH)
 - Subgroup 1.4.6: Weighing scales (WEG)

- Subgroup 1.4.7: Glucose meter (GL)
- Subgroup 1.4.8: Cardiovascular fitness and activity monitor (CV)
- Subgroup 1.4.9: Strength fitness equipment (ST)
- Subgroup 1.4.10: Independent living activity hub (HUB)
- Subgroup 1.4.11: Adherence monitor (AM)
- Subgroup 1.4.12: Peak expiratory flow monitor (PF)
- Subgroup 1.4.13: Body composition analyser (BCA)
- Subgroup 1.4.14: Basic electrocardiograph (ECG)
- Subgroup 1.4.15: International normalized ratio (INR)
- Subgroup 1.4.16: Sleep apnoea breathing therapy equipment (SABTE)
- Subgroup 1.4.17: Insulin pump (IP)
- Subgroup 1.4.18: Continuous glucose monitor (CGM)
- Group 1.5: Consent Management (CM)
 - Subgroup 1.5.1: HFS XDR transaction (TRANS)
 - Subgroup 1.5.2: HFS metadata validation (META)
 - Subgroup 1.5.3: HFS consent directive validation (CDV)
- Group 1.6: hData Observation Upload (HDATA)
 - Subgroup 1.6.1: General (GEN)
- Group 1.7: Questionnaires (QUE)
 - Subgroup 1.7.1: General (GEN)
 - Subgroup 1.7.2: CDA validation (CDA)
- Group 1.8: Capability Exchange (CE)
 - Subgroup 1.8.1: General (GEN)
 - Subgroup 1.8.2: hData record format (HRF)
- Group 1.9: FHIR Observation Upload (FHIR)
 - Subgroup 1.9.1: General (GEN)
 - Subgroup 1.9.2: FHIR Encoding Guidelines (ENC)
- Group 2: HFS receiver (HFSR)
 - Group 2.1: Web service interoperability (WSI)
 - Subgroup 2.1.1: Basic profile (BP)
 - Subgroup 2.1.2: Basic security profile (BSP)
 - Subgroup 2.1.3: Reliable messaging (RM)
 - Group 2.2: SOAP (SOAP)
 - Subgroup 2.2.1: SOAP headers (HEAD)
 - Group 2.3: Audit (ATNA)
 - Subgroup 2.3.1: General (GEN)
 - Subgroup 2.3.2: PCD-01 (PCD-01)
 - Subgroup 2.3.3: Consent Management (CM)
 - Group 2.4: PCD-01 HL7 messages (PCD-01-DATA)
 - Subgroup 2.4.1: General (GEN)
 - Subgroup 2.4.2: Design guidelines (DG)

- Subgroup 2.4.3: Pulse oximeter (PO)
- Subgroup 2.4.4: Blood pressure monitor (BPM)
- Subgroup 2.4.5: Thermometer (TH)
- Subgroup 2.4.6: Weighing scales (WEG)
- Subgroup 2.4.7: Glucose meter (GL)
- Subgroup 2.4.8: Cardiovascular fitness and activity monitor (CV)
- Subgroup 2.4.9: Strength fitness equipment (ST)
- Subgroup 2.4.10: Independent living activity hub (HUB)
- Subgroup 2.4.11: Adherence monitor (AM)
- Subgroup 2.4.12: Peak expiratory flow monitor (PF)
- Subgroup 2.4.13: Body composition analyser (BCA)
- Subgroup 2.4.14: Basic electrocardiograph (ECG)
- Subgroup 2.4.15: International normalized ratio (INR)
- Subgroup 2.4.16: Sleep apnoea breathing therapy equipment (SABTE)
- Subgroup 2.4.17: Insulin pump (IP)
- Subgroup 2.4.18: Continuous glucose monitor (CGM)
- **Group 2.5: Consent Management (CM)**
 - Subgroup 2.5.1: HFS XDR transaction (TRANS)
 - Subgroup 2.5.2: HFS service validation (SER)
- **Group 2.6: hData Observation Upload (HDATA)**
 - Subgroup 2.6.1: General (GEN)
 - Subgroup 2.6.2: hData record format (HRF)
- **Group 2.7: Questionnaires (QUE)**
 - Subgroup 2.7.1: General (GEN)
 - Subgroup 2.7.2: CDA validation (CDA)
 - Subgroup 2.7.3: hData record format (HRF)
- **Group 2.8: Capability Exchange (CE)**
 - Subgroup 2.8.1: General (GEN)
 - Subgroup 2.8.2: hData record format (HRF)
- **Group 2.9: FHIR Observation Upload (FHIR)**
 - **Subgroup 2.9.1: General (GEN)**

7 Electronic attachment

The protocol implementation conformance statements (PICSs) and the protocol implementation extra information for testing (PIXIT) required for the implementation of Annex A can be downloaded from <http://handle.itu.int/11.1002/2000/12067>. See [b-HFSR PICS & PIXIT] and [b-HFSS PICS & PIXIT].

In the electronic attachment, letters "C" and "I" in the column labelled "Mandatory" are used to distinguish between "PICS" and "PIXIT", respectively, during testing. If the cell is empty, the corresponding PICS is "independent". If the field contains a "C", the corresponding PICS is dependent on other PICSs, and the logical expression is detailed in the "SCR_Expression" field. The static conformance review (SCR) is used in the test tool to assert whether the PICS selection is consistent.

Annex A

Test procedures

(This annex forms an integral part of this Recommendation.)

A.1 Test purpose definition conventions

The TPs are defined according to the following rules:

- **TP Id:** This is a unique identifier (TP/<TT>/<DUT>/<GR>/<SGR>/<XX> – <NNN>). It is specified according to the naming convention defined below:
Each TP identifier is introduced by the prefix "TP".
 - <TT>: This is the test tool that will be used in the test case.
 - HFS: Health & Fitness Services Interface
 - <DUT>: This is the device under test.
 - SEN: HFS sender
 - REC: HFS receiver
 - <GR>: This identifies a group of test cases.
 - <SGR>: This identifies a subgroup of test cases.
 - <XX>: This identifies the type of testing.
 - BV: Valid behaviour test
 - BI: Invalid behaviour test
 - <NNN>: This is a sequential number that identifies the TP.
- **TP label:** This is the title of the TP.
- **Coverage:** This contains the specification reference and clause to be checked by the TP.
 - Spec: This indicates the earliest version of the specification from which the testable items to be checked by the TP were included.
 - Testable item: This contains testable items to be checked by the TP.
- **Test purpose:** This is a description of the requirements to be tested.
- **Applicability:** This contains the PICS items that define if a test case is applicable or not for a specific device. When a TP contains an "ALL" in this field it means that it applies to the DUT within that scope of the test (specialization, transport used, etc.).
- **Other PICSs:** This contains additional PICS items (apart from the PICS specified in the Applicability row) which are used within the test case implementation and can modify the final verdict. When this row is empty, it means that only the PICSs specified in the Applicability row are used within the test case implementation.
- **Initial condition:** This indicates the state to which the DUT needs to be moved at the beginning of TC execution.
- **Test procedure:** This describes the steps to be followed in order to execute the test case.
- **Pass/Fail criteria:** This provides criteria to decide whether the DUT passes or fails the test case.

A.2 Subgroup 2.9.1: General (GEN)

TP Id		TP/HFS/REC/FHIR/GEN/BV-000		
TP label		FHIR Observation Server support		
Coverage	Spec	[ITU-T H.812]		
	Testable items	RESTSec 7;M	RESTSec 8;M	CommonReq 5;M
	Spec	[b-ITU-T HSTP-H812-FHIR (2019)]		
	Testable items	FOSReq 1; M	FOSReq 2; M	HFSCCommon 6; M
		HFSCCommon 5; M	HFSCCommon 6; M	HFSCCommon 7; M
		HFSCCommon 8; M	HFSCCommon 9; M	HFSCCommon 10; M
		HFSCCommon 11; M	HFSCCommon 12; M	HFSCCommon 13; M
		HFSCCommon 14; M	HFSCCommon 15; M	HFSCCommon 16; M
HFSCCommon 17; O		HFSCCommon 18; M	HFSCCommon 19; M	
HFSCCommon 20; O				
Test purpose		<p>Check that:</p> <p>The root.xml file for the H&FS under test contains all required elements for the support of the FHIR Observation Server Continua Certified Capability Class, the H&FS is able to provide the OAuthDescriptor in JSON or XML format and it contains the required elements.</p>		
Applicability		C_REC_000 AND C_REC_GEN_007		
Other PICSS				
Initial condition		The simulated PHG supporting FHIR Observation Client and Capability Exchange Continua Certified Capability Classes is ready to request the root file of the H&FS under test using TLS 1.1.		
Test procedure		<ol style="list-style-type: none"> 1. The simulated PHG performs an HTTP GET of root.xml using TLS v.1.1. 2. The simulated PHG obtains the root.xml file of the H&FS under test and checks that: <ol style="list-style-type: none"> a) There is a <profile> element in which: <ul style="list-style-type: none"> • <id> element has a value of "FHIR-Observation-Server-4C". • <reference> elements points to the latest revision of the hData Content Profile document that the implementation supports b) There is a <resourceType> element in which: <ul style="list-style-type: none"> • <resourceTypeID> element has a value of "OAuthDescriptor". • <reference> elements points to the latest revision of the reference document that the implementation supports • <representation> element has a <mediaType> element which value is "application/json" or "application/xml". c) There is a <section> element in which: <ul style="list-style-type: none"> • <profileID> has a value of "FHIR-Observation-Server-4C". • <resourceTypeID> has a value of "OAuthDescriptor". • <resourcePrefix> has a value of "true". • <path> element contains an atom feed to get the OAuthDescriptor. 3. The simulated PHG retrieves the atom feed returned by the H&FS and checks that: 		

	<p>a) There is (at least) one OAuthDescriptor listed.</p> <p>4. The simulated PHG retrieves the OAuthDescriptor (in XML or JSON format) using the link element of the atom feed and checks that:</p> <p>a) There is a resourceServerURL element which value is an URL (the endpoint where the H&FS expects to receive measurements).</p> <p>b) There is a tokenEndpointURL element which value is an URL (the endpoint for obtaining the bearer OAuth token).</p> <p>c) There is a grantTypes element and it contains one or more of the following strings:</p> <ul style="list-style-type: none"> • "clientCredential" • "resourceOwnerCredential" • "implicit" • "authorizationCode" <p>d) Additionally, the grantTypes element may contain:</p> <ul style="list-style-type: none"> • "rfc7523" <p>e) There may be an authorizationEndpointURL element which value is an URL (the OAuth endpoint the H&FS expects the PHG to use for OAuth authorization).</p>
Pass/Fail criteria	<ul style="list-style-type: none"> • The root file contains all the elements and values described in step 2. • The provided atom feed contains at least one OAuthDescriptor listed. • The OAuthDescriptor can be retrieved using the link element in the atom feed. • The OAuthDescriptor is compliant to the description given in step 4. • If the <mediaType> element of the <resourceType>with a <resourceTypeID> value of "OAuthDescriptor" is set to application/xml the OAuthDescriptor will be retrieved in XML format. • If the <mediaType> element of the <resourceType>with a <resourceTypeID> value of "OAuthDescriptor" is set to application/json the OAuthDescriptor will be retrieved in JSON format.
Notes	

TP Id	TP/HFS/REC/FHIR/GEN/BV-001			
TP label	FHIR Observation Reporting Server support			
Coverage	Spec	[ITU-T H.812]		
	Testable items	RESTSec 7;M	RESTSec 8;M	CommonReq 5;M
	Spec	[b-ITU-T HSTP-H812-FHIR (2019)]		
	Testable items	FORSReq 1; M	FORSReq 2; M	HFSCCommon 6; M
		HFSCCommon 5; M	HFSCCommon 6; M	HFSCCommon 7; M
		HFSCCommon 8; M	HFSCCommon 9; M	HFSCCommon 10; M
		HFSCCommon 11; M	HFSCCommon 12; M	HFSCCommon 13; M
		HFSCCommon 14; M	HFSCCommon 15; M	HFSCCommon 16; M
HFSCCommon 17; O		HFSCCommon 18; M	HFSCCommon 19; M	
HFSCCommon 20; O				

Test purpose	Check that: The root.xml file for the H&FS under test contains all required elements for the support of the FHIR Observation Reporting Server Continua Certified Capability Class, the H&FS is able to provide the OAuthDescriptor in JSON or XML format and it contains the required elements.
Applicability	C_REC_000 AND C_REC_GEN_008
Other PICSS	
Initial condition	The simulated PHG supporting FHIR Observation Reporting Client Continua Certified Capability Class is ready to request the root file of the H&FS under test using TLS 1.1.
Test procedure	<ol style="list-style-type: none"> 1. The simulated PHG performs an HTTP GET of root.xml using TLS v.1.1. 2. The simulated PHG obtains the root.xml file of the H&FS under test and checks that: <ol style="list-style-type: none"> a) There is a <profile> element in which: <ul style="list-style-type: none"> • <id> element has a value of "FHIR-Observation-Reporting-Server-4C". • <reference> elements points to the latest revision of the hData Content Profile document that the implementation supports b) There is a <resourceType> element in which: <ul style="list-style-type: none"> • <resourceTypeID> element has a value of "OAuthDescriptor". • <reference> elements points to the latest revision of the reference document that the implementation supports. • <representation> element has a <mediaType> element which value is "application/json" or "application/xml". c) There is a <section> element in which: <ul style="list-style-type: none"> • <profileID> has a value of "FHIR-Observation-Reporting-Server-4C". • <resourceTypeID> has a value of "OAuthDescriptor". • <resourcePrefix> has a value of "true". • <path> element contains an atom feed to get the OAuthDescriptor- 3. The simulated PHG retrieves the atom feed returned by the H&FS and checks that: <ol style="list-style-type: none"> a) There is (at least) one OAuthDescriptor listed. 4. The simulated PHG retrieves the OAuthDescriptor (in XML or JSON format) using the link element of the atom feed and checks that: <ol style="list-style-type: none"> a) There is a resourceServerURL element which value is an URL (the endpoint where the H&FS expects to receive measurements). b) There is a tokenEndpointURL element which value is an URL (the endpoint for obtaining the bearer OAuth token). c) There is a grantTypes element and it contains one or more of the following strings: <ul style="list-style-type: none"> • "clientCredential" • "resourceOwnerCredential" • "implicit" • "authorizationCode" d) Additionally, the grantTypes element may contain: <ul style="list-style-type: none"> • "rfc7523" e) There may be an authorizationEndpointURL element which value is an URL (the OAuth endpoint the H&FS expects the PHG to use for OAuth authorization).
Pass/Fail criteria	<ul style="list-style-type: none"> • The root file contains all the elements and values described in step 2. • The provided atom feed contains at least one OAuthDescriptor listed. • The OAuthDescriptor can be retrieved using the link element in the atom feed.

	<ul style="list-style-type: none"> • The OAuthDescriptor is compliant to the description given in 4. • If the <mediaType> element of the <resourceType>with a <resourceTypeID> value of "OAuthDescriptor" is set to application/xml the OAuthDescriptor will be retrieved in XML format. • If the <mediaType> element of the <resourceType>with a <resourceTypeID> value of "OAuthDescriptor" is set to application/json the OAuthDescriptor will be retrieved in JSON format.
Notes	

TP Id	TP/HFS/REC/FHIR/GEN/BV-002			
TP label	OAuth support			
Coverage	Spec	[ITU-T H.812]		
	Testable items	RESTSec 7;M	RESTSec 8;M	CommonReq 5;M
	Spec	[b-ITU-T HSTP-H812-FHIR (2019)]		
	Testable items	HFSCCommon 1; M	HFSCCommon 2; M	HFSCCommon 3; C
		HFSCCommon 22; M	HFSCCommon 23; M	HFSCCommon 24; M
Test purpose	<p>Check that:</p> <p>The H&FS under accepts the upload of a FHIR measurement (as a complete transaction bundle) using the supported OAuth authorization grant types.</p>			
Applicability	C_REC_000 AND (C_REC_GEN_007 OR C_REC_GEN_008)			
Other PICSS	C_REC_FHIR_001			
Initial condition	The simulated PHG supporting FHIR Observation Reporting Client Continua Certified Capability Class is ready to perform a conditional create operation to upload a complete FHIR bundle (with no external references) to the H&FS under test. PHG has previously retrieved both the root file and the OAuthDescriptor from the H&FS under test.			
Test procedure	<ol style="list-style-type: none"> 1. The simulated PHG performs a create operation (HTTP POST) to upload a complete FHIR bundle (in XML format) containing a new measurement using TLS 1.1 and an OAuth 2.0 bearer token obtained using the client credentials grant type. 2. The H&FS accepts the request and returns <HTTP 201> (Created). 3. The simulated PHG performs a create operation (HTTP POST) to upload a complete FHIR bundle (in JSON format) containing a new measurement using TLS 1.1 and an OAuth 2.0 bearer token obtained using the resource owner credentials grant type. 4. The H&FS accepts the request and returns <HTTP 201> (Created). <p>IF C_REC_FHIR_001=TRUE continue with step 5, ELSE the test case ends.</p> <ol style="list-style-type: none"> 5. The simulated PHG performs a create operation (HTTP POST) to upload a complete FHIR bundle (in XML format) containing a new measurement using TLS 1.1 and an OAuth 2.0 bearer token obtained using the authorization code grant type. 6. The H&FS accepts the request and returns <HTTP 201> (Created). 7. The simulated PHG performs a create operation (HTTP POST) to upload a complete FHIR bundle (in JSON format) containing a new measurement using TLS 1.1 and an OAuth 2.0 bearer token obtained using the implicit grant type. 8. The H&FS accepts the request and returns <HTTP 201> (Created). 			

Pass/Fail criteria	<ul style="list-style-type: none"> The H&FS under test accepts the requests as described in steps 2 and 4, and, if C_REC_FHIR_001=TRUE, it also accepts the requests as described in steps 6 and 8.
Notes	

TP Id	TP/HFS/REC/FHIR/GEN/BV-003			
TP label	JSON Web Token support			
Coverage	Spec	[ITU-T H.812]		
	Testable items	RESTSec 7;M	RESTSec 8;M	CommonReq 5;M
	Spec	[b-ITU-T HSTP-H812-FHIR (2019)]		
	Testable items	HFSCCommon 20; C	HFSCCommon 21; M	
Test purpose	<p>Check that:</p> <p>If the H&FS contains the "rfc7523" string in the grantTypes element of its OAuthDescriptor, it shall accept a valid JWT as an authorization grant.</p> <p>[AND]</p> <p>If an invalid JWT is provided, the H&FS shall provide information regarding the error in the response.</p>			
Applicability	C_REC_000 AND (C_REC_GEN_007 OR C_REC_GEN_008)			
Other PICSS	C_REC_FHIR_002			
Initial condition	The simulated PHG supporting FHIR Observation Reporting Client Continua Certified Capability Class is ready to retrieve the OAuthDescriptor of the H&FS and to perform a conditional create operation to upload a complete FHIR bundle (with no external references). PHG has previously retrieved the root file from the H&FS under test.			
Test procedure	<ol style="list-style-type: none"> The simulated PHG retrieves the OAuthDescriptor (in XML or JSON format) using the link element of the atom feed provided by the root file of the H&FS under test. The simulated PHG checks that the grantTypes element of the OAuthDescriptor contains the string "rfc7523". The simulated PHG performs a create operation (HTTP POST) to upload a complete FHIR bundle containing a new measurement using TLS 1.1 and a single valid JSON Web Token. The H&FS accepts the request and returns <HTTP 201> (Created). The simulated PHG performs a create operation (HTTP POST) to upload a complete FHIR bundle containing a new measurement using TLS 1.1 and an invalid JSON Web Token. The H&FS does not accept the request and returns an error (i.e. an <HTTP 400> (Bad Request)) with additional information using the "error_description" or "error_uri" parameters. 			
Pass/Fail criteria	<ul style="list-style-type: none"> The OAuthDescriptor contains the "rfc7523" string in step 2. The H&FS accepts the operation as described in step 4. The H&FS rejects the operation and provides information about the error as described in step 6. 			
Notes				

TP Id	TP/HFS/REC/FHIR/GEN/BV-004		
TP label	FHIR API Support for FHIR Operation Server		
Coverage	Spec	[ITU-T H.812]	
	Testable items	RESTSec 7;M	RESTSec 8;M CommonReq 5;M
	Spec	[b-ITU-T HSTP-H812-FHIR (2019)]	
	Testable items	HFSCCommon 2; M	FOSReq 3; M
Test purpose	Check that: A FHIR Observation Server shall support a minimum set of FHIR operations as defined by [RESTful FHIR]:		
Applicability	C_REC_000 AND C_REC_GEN_007		
Other PICs			
Initial condition	The simulated PHG supporting FHIR Observation Reporting Client Continua Certified Capability Class is ready to perform a conditional create operation to upload a complete FHIR bundle with an Observation resource (with no external references) to the H&FS under test. PHG has previously retrieved both the root file and the OAuthDescriptor from the H&FS under test. The H&FS under test have no previously stored resources.		
Test procedure	<ol style="list-style-type: none"> 1. The simulated PHG performs a create operation (HTTP POST) to upload a complete FHIR bundle containing an Observation resource (using TLS 1.1 and an OAuth 2.0 bearer token obtained using the client credentials grant type). 2. The H&FS accepts the request and returns <HTTP 201> (Created) and a Location header, which contains the new Logical Id and Version Id of the created resources. 3. The simulated PHG performs a conditional create operation (HTTP POST) using the HL7 defined extension header "If-None-Exist" to upload a FHIR Observation resource (which references can be resolved within the H&FS) using TLS 1.1 and an OAuth 2.0 bearer token obtained using the client credentials grant type. The simulated PHG uses a non-existent Logical Id (other than the ones returned in step 2) as the search parameter in the "If-None-Exist" header. 4. The H&FS accepts the request and returns <HTTP 201> (Created) and a Location header, which contains the new Logical Id and Version Id of the created resource version. 5. The simulated PHG performs a conditional create operation (HTTP POST) using the HL7 defined extension header "If-None-Exist" to upload the same FHIR Observation Resource as in step 3 (using TLS 1.1 and an OAuth 2.0 bearer token obtained using the client credentials grant type). The simulated PHG uses Logical Id obtained in step 4 as the search parameter in the "If-None-Exist" header. 6. The H&FS ignores the operation as it finds a match and returns <HTTP 200> (OK). 7. The simulated PHG performs an update operation (HTTP PUT) to update the FHIR Observation resource uploaded in step 3 (using TLS 1.1 and an OAuth 2.0 bearer token obtained using the client credentials grant type). This operation uses a non-existent id (not the one obtained in step 4) 8. The H&FS creates the resource (as no resource already exists for the given id) and returns <HTTP 201> (Created) and a Location header, which contains the new Logical Id and Version Id of the created resource version 9. The simulated PHG performs an update operation (HTTP PUT) to update the FHIR Observation resource uploaded in step 3 (using TLS 1.1 and an OAuth 2.0 bearer token obtained using the client credentials grant type). This operation uses the id obtained in step 4. 10. The H&FS accepts the request, updates the resource, and returns an <HTTP 200> (OK) status code. 		

	<ol style="list-style-type: none"> 11. The simulated PHG performs a capabilities operation (HTTP GET) to retrieve the server's Capability Statement that defines how it supports resources (using TLS 1.1 and an OAuth 2.0 bearer token obtained using the client credentials grant type). 12. The H&FS returns a Capability Statement that specifies which resource types and interactions are supported for the GET command. 13. The simulated PHG performs a transaction operation (HTTP PUT) to update the resource uploaded in 3 and to upload (create) a new measurement resource with known references (using TLS 1.1 and an OAuth 2.0 bearer token obtained using the client credentials grant type). 14. The H&FS accepts the transaction operation and returns a successful response as both operations succeeded.
Pass/Fail criteria	<ul style="list-style-type: none"> • The H&FS accepts the operations and responds as described in step 2, 4, 6, 8, 10, 12 and 14.
Notes	

Bibliography

- [b-ITU-T H.810 (2013)] Recommendation ITU-T H.810 (2013), *Interoperability design guidelines for personal health systems*.
- [b-ITU-T H.810 (2015)] Recommendation ITU-T H.810 (2015), *Interoperability design guidelines for personal health systems*.
- [b-ITU-T H.810 (2016)] Recommendation ITU-T H.810 (2016), *Interoperability design guidelines for personal health systems*.
- [b-ITU-T H.811] Recommendation ITU-T H.811 (2017), *Interoperability design guidelines for personal connected health systems: Personal Health Devices interface*.
- [b-ITU-T H.812.1] Recommendation ITU-T H.812.1 (2017), *Interoperability design guidelines for personal connected health systems: Services interface: Observation upload capability*.
- [b-ITU-T H.812.2] Recommendation ITU-T H.812.2 (2017), *Interoperability design guidelines for personal connected health systems: Services interface: Questionnaire capability*.
- [b-ITU-T H.812.3] Recommendation ITU-T H.812.3 (2017), *Interoperability design guidelines for personal connected health systems: Services interface: Capability Exchange capability*.
- [b-ITU-T H.812.4] Recommendation ITU-T H.812.4 (2017), *Interoperability design guidelines for personal connected health systems: Services interface: Authenticated Persistent Session capability*.
- [b-ITU-T H.813] Recommendation ITU-T H.813 (2017), *Interoperability design guidelines for personal connected health systems: Healthcare Information System interface*.
- [b-HSTP-H812-FHIR 2019] HSTP-H812-FHIR (2019), [Interoperability design guidelines for personal health systems: Services interface: FHIR Observation Upload for trial implementation](#). Available [viewed 2019-11-22] at: <http://www.itu.int/pub/T-TUT-EHT-2019-H812FHIR>
- [b-CDG 1.0] Continua Health Alliance, Continua Design Guidelines v1.0 (2008), *Continua Design Guidelines*.
- [b-CDG 2010] Continua Health Alliance, Continua Design Guidelines v1.5 (2010), *Continua Design Guidelines*.
- [b-CDG 2011] Continua Health Alliance, Continua Design Guidelines (2011), "Adrenaline", *Continua Design Guidelines*.
- [b-CDG 2012] Continua Health Alliance, Continua Design Guidelines (2012), "Catalyst", *Continua Design Guidelines*.
- [b-CDG 2013] Continua Health Alliance, Continua Design Guidelines (2013), "Endorphin", *Continua Design Guidelines*.
- [b-CDG 2015] Continua Health Alliance, Continua Design Guidelines (2015), "Genome", *Continua Design Guidelines*.
- [b-CDG 2016] Personal Connected Health Alliance, Continua Design Guidelines (2016), "Iris", *Continua Design Guidelines*.
- [b-ETSI SR 001 262] ETSI SR 001 262 v1.8.1 (2003), . <https://docbox.etsi.org/MTS/MTS/10-PromotionalMaterial/MBS-20111118/Referenced%20Documents/Drafting%20Rules.pdf>

- [b-HFSR PICS & PIXIT] HFS Receiver PICS and PIXIT Test Tool v7.0.0.0 – Excel sheet v1.8.
<https://handle.itu.int/11.1002/2000/12067>
- [b-HFSS PICS & PIXIT] HFS Sender PICS and PIXIT Test Tool v7.0.0.0 – Excel sheet v1.8.
<<https://handle.itu.int/11.1002/2000/12067>>
- [b-HL7 V3 HRF] Health Level Seven (2014), *HL7 Version 3 Specification: hData Record Format, Release 1*.
http://www.hl7.org/documentcenter/private/standards/v3/V3_ITS_HDATA_RF_R1_2014JUN.pdf
- [b-IETF RFC 3339] IETF RFC 3339 (2002), *Date and time on the Internet: Timestamps*.
<https://datatracker.ietf.org/doc/rfc3339>

SERIES OF ITU-T RECOMMENDATIONS

Series A	Organization of the work of ITU-T
Series D	Tariff and accounting principles and international telecommunication/ICT economic and policy issues
Series E	Overall network operation, telephone service, service operation and human factors
Series F	Non-telephone telecommunication services
Series G	Transmission systems and media, digital systems and networks
Series H	Audiovisual and multimedia systems
Series I	Integrated services digital network
Series J	Cable networks and transmission of television, sound programme and other multimedia signals
Series K	Protection against interference
Series L	Environment and ICTs, climate change, e-waste, energy efficiency; construction, installation and protection of cables and other elements of outside plant
Series M	Telecommunication management, including TMN and network maintenance
Series N	Maintenance: international sound programme and television transmission circuits
Series O	Specifications of measuring equipment
Series P	Telephone transmission quality, telephone installations, local line networks
Series Q	Switching and signalling, and associated measurements and tests
Series R	Telegraph transmission
Series S	Telegraph services terminal equipment
Series T	Terminals for telematic services
Series U	Telegraph switching
Series V	Data communication over the telephone network
Series X	Data networks, open system communications and security
Series Y	Global information infrastructure, Internet protocol aspects, next-generation networks, Internet of Things and smart cities
Series Z	Languages and general software aspects for telecommunication systems